



## Consumer Confidence Report for Calendar Year 2022

Este informe contiene información muy importante sobre el agua usted bebe.  
Tradúscalo ó hable con alguien que lo entienda bien.

Public Water System ID Number	Public Water System Name		
AZ04-11-321	VILLA GRANDE DOMESTIC WATER IMPROVEMENT DISTRICT		
Contact Name and Title	Phone Number	E-mail Address	
JONI ROERDINK	520-251-0481	villagrandedwid@gmail.com	

We want our valued customers to be informed about their water quality. If you would like to learn more about public participation or to attend any of our regularly scheduled meetings, please contact Joni Roerdink at 520-251-0481 for additional opportunity and meeting dates and times.

### Drinking Water Sources

The sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

<b>Our water source(s):</b>	<i>The system has two wells, which are currently proving water for the system. We currently draw water from the aquifer in the Pinal AMA.</i>
-----------------------------	---

### Drinking Water Contaminants

**Microbial Contaminants:** Such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife

**Inorganic Contaminants:** Such as salts and metals that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming

**Pesticides and Herbicides:** Such as agriculture, urban storm water runoff, and residential uses that may come from a variety of sources

**Organic Chemical Contaminants:** Such as synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and also may come from gas stations, urban storm water runoff, and septic systems.

**Radioactive Contaminants:** That can be naturally occurring or be the result of oil and gas production and mining activities.

## Vulnerable Population

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. Some people may be more vulnerable to contaminants in drinking water than the general population.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV-AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers.

For more information about contaminants and potential health effects, or to receive a copy of the U.S. Environmental Protection Agency (EPA) and the U.S. Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and microbiological contaminants call the EPA *Safe Drinking Water Hotline* at 1-800-426-4791.

## Source Water Assessment

- The department has given a low risk designation for the degree to which this public water system drinking water source(s) are protected. A low risk designation indicates that most source water protection measures are either already implemented, or the hydrogeology is such that the source water protection measures will have little impact on protection.

## Definitions

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water

**Level 1 Assessment:** A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria was present

**Level 2 Assessment:** A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria was present

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment, or other requirements

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health

**Maximum Residual Disinfectant Level (MRDL):** The level of disinfectant added for water treatment that may not be exceeded at the consumer's tap

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of disinfectant added for treatment at which no known or anticipated adverse effect on health of persons would occur

**Minimum Reporting Limit (MRL):** The smallest measured concentration of a substance that can be reliably measured by a given analytical method

**Millirems per year (MREM):** A measure of radiation absorbed by the body

**Not Applicable (NA):** Sampling was not completed by regulation or was not required

**Not Detected (ND or <):** Not detectable at reporting limit

**Nephelometric Turbidity Units (NTU):** A measure of water clarity

**Million fibers per liter (MFL)**

**Picocuries per liter (pCi/L):** Measure of the radioactivity in water

**ppm:** Parts per million or Milligrams per liter (mg/L)

**ppb:** Parts per billion or Micrograms per liter (µg/L)

**ppt:** Parts per trillion or Nanograms per liter (ng/L)

**ppq:** Parts per quadrillion or Picrograms per liter (pg/L)

ppm x 1000 = ppb

ppb x 1000 = ppt

ppt x 1000 = ppq

## Lead Informational Statement:

Lead, in drinking water, is primarily from materials and components associated with service lines and home plumbing. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. VILLA GRANDE DWID is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at [www.epa.gov/safewater/lead](http://www.epa.gov/safewater/lead).

## Water Quality Data – Regulated Contaminants

Microbiological (RTCR)	TT Violation Y or N	Number of Positive Samples	Positive Sample(s) Month & Year	MCL	MCLG	Likely Source of Contamination
E. Coli	N	0	0	0	0	Human and animal fecal waste

<b>Fecal Indicator</b> (coliphage, enterococci and/or E. coli)	N	0	0	0	0	Human and animal fecal waste	
<b>Disinfectants</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA)</b>	<b>Range of All Samples (Low-High)</b>	<b>MRDL</b>	<b>MRDLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Chlorine/Chloramine (ppm)	N	0.03	0.01-.006	4	0	MONTHLY 2022	Water additive used to control microbes
<b>Disinfection By-Products</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Haloacetic Acids (HAA5) (ppb)	N	<2.0	<2.0	60	N/A	AUG 2022	Byproduct of drinking water disinfection
Total Trihalomethanes (TTHM) (ppb)	N	<.5	<.5	80	N/A	AUG 2022	Byproduct of drinking water disinfection
<b>Lead &amp; Copper</b>	<b>MCL Violation Y or N</b>	<b>90<sup>th</sup> Percentile</b>	<b>Number of Samples Exceeds AL</b>	<b>AL</b>	<b>ALG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Copper (ppm)	N	.35	0	1.3	1.3	AUG 2022	Corrosion of household plumbing systems; erosion of natural deposits
Lead (ppb)	Y	70	1	15	0	AUG 2022	Corrosion of household plumbing systems; erosion of natural deposits
<b>Radionuclides</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Alpha Emitters (pCi/L)	N	14.2	14.2	15	0	MAY 2022	Erosion of natural deposits
<b>Inorganic Chemicals (IOC)</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
Antimony (ppb)	N	0	0	6	6	MAY 2022	Discharge from petroleum refineries; fire retardants; ceramics, electronics and solder
Arsenic <sup>1</sup> (ppb)	N	2.6	2.6	10	0	MAY 2022	Erosion of natural deposits, runoff from orchards, runoff from glass and electronics production wastes
Asbestos (MFL)	N	0	0	7	7	MAY 2022	Decay of asbestos cement water mains; Erosion of natural deposits
Barium (ppm)	N	.042	.042	2	2	MAY 2022	Discharge of drilling wastes; discharge from metal refineries; Erosion of natural deposits
Beryllium (ppb)	N	0	0	4	4	MAY 2022	Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries
Cadmium (ppb)	N	0	0	5	5	MAY 2022	Corrosion of galvanized pipes; natural deposits; metal refineries; runoff from waste batteries and paints
Chromium (ppb)	N	3.2	3.2	100	100	MAY 2022	Discharge from steel and pulp mills; Erosion of natural deposits
Cyanide (ppb)	N	0	0	200	200	MAY 2022	Discharge from steel/metal factories; Discharge from plastic and fertilizer factories
Fluoride (ppm)	N	.16	.16	4	4	MAY 2022	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills and cropland

<b>Mercury (ppb)</b>	N	0	0	2	2	MAY 2022	Erosion of natural deposits; Discharge from refineries and factories; Runoff from landfills and cropland.
<b>Nitrate<sup>2</sup> (ppm)</b>	Y	18.6	16.2	10	10	2022	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Nitrite (ppm)</b>	N	0	0	1	1	MAY 2022	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
<b>Selenium (ppb)</b>	N	8.3	8.3	50	50	MAY 2022	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
<b>Sodium (ppm)</b>	N	130	130	N/A	N/A	2021	Erosion of natural deposits
<b>Thallium (ppb)</b>	N	0	0	2	0.5	MAY 2022	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories

<sup>1</sup> **Arsenic** is a mineral known to cause cancer in humans at high concentration and is linked to other health effects, such as skin damage and circulatory problems. If arsenic is less than or equal to the MCL, your drinking water meets EPA's standards. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water, and continues to research the health effects of low levels of arsenic.

<sup>2</sup> **Nitrate** in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause "blue baby syndrome." Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant, and detected nitrate levels are above 5 ppm, you should ask advice from your health care provider. **"Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated. For further information, please see footnote #2 under Inorganic Chemicals (IOC).**

<b>Synthetic Organic Chemicals (SOC)</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
<b>*ALL SOC's CAME BACK BELOW DETECTION LEVELS*</b>	N					MAY 2022	
<b>Volatile Organic Chemicals (VOC)</b>	<b>MCL Violation Y or N</b>	<b>Running Annual Average (RAA) OR Highest Level Detected</b>	<b>Range of All Samples (Low-High)</b>	<b>MCL</b>	<b>MCLG</b>	<b>Sample Month &amp; Year</b>	<b>Likely Source of Contamination</b>
<b>*ALL VOC's CAME BACK BELOW DETECTION LEVELS*</b>	N					MAY 2022	

#### Violation Summary (for MCL, MRDL, AL, TT, or Monitoring & Reporting Requirement)

<b>Violation Type</b>	<b>Explanation, Health Effects</b>	<b>Time Period</b>	<b>Corrective Actions</b>
<b>LEAD ACTION LEVEL EXCEEDANCE</b>	The 90 <sup>th</sup> percentile for lead exceeded the EPA's standards. Lead can interfere with the production of red blood cells that carry oxygen.	AUG-2022	Corrosion control and correcting sampling methods, to include additional sampling points to prevent mis-sampling.
<b>MAXIMUM CONTAMINANT LEVEL (MCL) VIOLATION NITRATE EXCEEDANCE</b>	Water samples showed that the amount of this contaminant in our drinking water was above its standard (called a maximum contaminant level and abbreviated MCL) for the period indicated. For further information, please see footnote #2 under Inorganic Chemicals (IOC).	JAN-DEC 2022	PROVIDING TOKENS FOR BOTTLE WATER-WORKING W/AZDEQ

*Please share this information with other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*